



Government of West Bengal  
Office of the Director General  
West Bengal Fire & Emergency Services  
13D, Mirza Ghalib Street, Kolkata – 16

Memo No.:FSR/0125186201103684

Date : 26-06-2025

From :  
Director  
Fire Prevention Wing,  
West Bengal Fire & Emergency Services

To :  
Bholananda National Academy  
C/o Sree Guru Bholananda Ashram Trust, Kankinara-Rafipur Padmalovepore Road, Panpur, P.S.-Basudebpur, Dist-24Pgs(N), Pin Code-743126.

Sub : Fire Safety Certificate of existing construction of G+IV and G+II storied building (both the building are interconnected in each respective floor level with M wide corridor) under group Educational Building in the name and style as "Bholananda National Academy" at the premises no. Sree Guru Bholananda Ashram Trust, Kankinara-Rafipur Padmalovepore Road, Panpur, Dist-24Pgs (N), Pin Code-743126.


This is in reference to your AIN 211892506300006537 dated 02-May-2025 regarding Fire Safety Certificate of existing construction of G+IV and G+II storied building (both the building are interconnected in each respective floor level with M wide corridor) under group Educational Building in the name and style as "Bholananda National Academy" at the premises no. Sree Guru Bholananda Ashram Trust, Kankinara-Rafipur Padmalovepore Road, Panpur, Dist-24Pgs (N), Pin Code-743126..

The performance of the Fire Fighting System as incorporated in the building were tested at random and found satisfactorily working condition. In view of the above this office is releasing the **Fire Safety Certificate** for occupancy of the aforesaid building.


**Recommendation:**

1. Entrance / Exit must be free of any type of obstruction for EASY movement of Fire Appliances. No parking will be allowed on the Drive way.
2. The Interior finish decoration of the building shall be made with low flame spread material confirming to the I.S. Specification.



  
Principal  
Bholananda National Academy  
Kankinara  
Panpur, 24 Pgs. (N), W.B. Pin-743126

The authenticity of this document can be verified by accessing the URL: [edistrict.wb.gov.in](http://edistrict.wb.gov.in) and then clicking on the Verification of Digitally Signed Document link and keying in the Unique Number : 211892506300006537

  
Manager  
Bholananda National Academy  
Kankinara  
Panpur, 24 Pgs. (N), W.B. Pin-743126



3. To eliminate risk of Fire Hazards, Good House Keeping both for insides and outside of the building shall be strictly maintained.
4. Existing Electrical wiring of the whole building shall have to be carefully checked for any wear and tear in them, particularly lines above false ceiling & ducts.
5. The notice of Fire Fighting and Evacuation from the building shall be prepared and displayed at all vulnerable places of the building.
6. All the vertical and horizontal ducts including all electrical ducts to be sealed by approved fire resistance materials.
7. A Fire control room including a closed circuit T.V. system shall have to be maintained which observe all floor of the building.
8. The employees and security staff shall be conversant with installed Fire Fighting equipment of the building and to operate in the event of Fire and Testing.
9. Mock Fire Practice and evacuation drill shall be performed periodically with participation of all the employees and security personnel of the station building.
10. Transformer, Switch Gear room, Electrical main and meter room, electrical panel room shall be protected with automatic Fire detection and suppression system conforming relevant I.S. Specification.
11. A crew of trained Fireman under and experience officer shall be maintained round the clock for safety of the building.
12. First-Aid Fire Fighting system shall be maintained as per I.S. Specification.
13. The management of the organization / building as the case may be shall maintain the fire prevention and safety measures in good repair and in efficient condition at all the times, which are installed in the building for use at the time of fire or other emergencies.
14. If required the old electrical lines shall have to be replaced with new lines. The cables shall always be laid in M.S. conduit pipes continuously bonded to the earth.
15. Periodical flashing of water from water based suppression system shall be made to maintain the efficient working performance of above mentioned system.
16. All the fire pumps shall always be kept in auto mode.
17. Any addition / alteration in construction and changes the nature of use of the occupancy in respect of the approved plan drawing, without obtaining prior permission from this office, this Renewal of Fire Safety Certificate will be treated as cancelled.
18. Fire License shall have to be obtained from competent authority for storing and processing of LPG and other combustible and inflammable articles (if any).
19. Fire Safety audit and Electrical Safety audit to be conducted at regular interval and to be recorded in the Fire Prevention maintenance register.
20. This renewal of Fire Safety Certificate is valid for 03 (Three) Years from the date of issue of this letter and has to be renewed within validity limit.
21. Accordingly, a certificate is to be obtained from the **Director General, West Bengal Fire & Emergency Services** regarding performance of all the Fire and Life Safety arrangements and installations of the building.

Valid Upto : 24-Jun-2028



**Principal**  
**Bholananda National Academy**  
**Kankinara**  
**Panpur, 24 Pgs. (N), W.B. Pin-743126**



**Signature valid**

Digitally Signed.  
Name: ABHINAV PANDEY  
Date: 26-Jun-2023 13:17:39  
Reason: D-Sign  
Location: E-Dist 2.0

**Director**

**West Bengal Fire & Emergency Services**

The authenticity of this document can be verified by accessing the URL: [edistrict.wb.gov.in](http://edistrict.wb.gov.in) and then clicking on the Verification of Digitally Signed Document link and keying in the Unique Number : 211892506300006537

  
**Manager**  
**Bholananda National Academy**  
**Kankinara**  
**Panpur, 24 Pgs. (N), W.B. Pin-743126**